

**Proposal 17711
For
Furnace and A/C unit for the Ames DOT District 1 maintenance facility
Questions and Responses Set 1**

Q1) How much headroom is up above the break room?

R1) There is at least 12' it could be as much as 15'.

Q2 Does the vent go through the roof?

R2) Yes

Q3) Are you going to reuse the line sets and vent piping?

R3) Yes, if you find the line sets and vent pipe is still in good shape then we can re-use them.

Q4) Working hours is there any flexibility?

R4) Yes, we can look into some flexibility in the hours.

Q5) Does the thermostat need to be replaced?

R5) No, that is not part of the proposal.

Q6) Does it use LP?

R6) Yes

Q7) Are you looking for brand specific?

R7) No, it must meet the specified minimums. See addendum 1 for furnace specifications

Q8).Do you need low ambient controls?

R8) Yes